



कार्यालय
नगर परिषद, चिमूर
ता.चिमूर, ज़िचंद्रपूर



फोन.नं. ०७९७०-२६५०७० E-mail npchimur@gmail.com

जा.क्र.न.प.ची/बांध.वि./2025/ 392

दिनांक :- 17 / 03 / 2025

FIRE SAFETY CERTIFICATE

Reference: - Maharashtra Fire Prevention and Life Safety Measures Act
2006 & Maharashtra Fire Prevention Life Safety Rule 2009.

This is to certify that as per application Submitted by **St. Claret English Medium School** situated At Wadala Paiku, Chimur Tah. Chimur Dist Chandrapur and an audit report given by Licensed Fire Agency, which has been authorized by Directorate of Fire Services, Mumbai and an inspection report submitted by for dept. of Municipal council Chimur the said institute has been seen to be installed Centrifugal Monoblock Booster Pump of 900 LPM with Motor 1 Nos., DOL Starter For Booster Fire Pump With Cable Nos. 1, Hose Reel Drum Units With 20MM Dia. Rubber Hoses 30 M Long & 19 MM 7 Nos., 2 Nos. CO₂ 4.5 Kg. & 9 Nos. ABC/DCP 9 Kg., Manual Operated Fire Alarm Siren(Fire Bus) 1 Nos. & Signages 12 Nos fire prevention tools & safety measure equipment's.

This Certificate is Valid till up to :- **15/09/2025.**




Civil Engineer
Municipal Council, Chimur